



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

KFD2-SL2-Ex1.LK. Single-Channel Solenoid Driver.

NI / I / 2 / ABCD / T4, Ta = 60°C

I / 2 / Ex nA nC / IIC / T4, Ta = 60°C

AIS / I,II,III / 1 / ABCDEFG - 16-562FM-12; Entity

[I / 0] / Ex [ia] / IIC

Entity Parameters: See Table

Gas Group	Voc, Uo (V)	Isc, Io (mA)	Po (mW)	Ca, Co (nF)	La, Lo (mH)	Lo/Ro (uH/Ohm)
Groups A/B (IIC)	28	110	770	83	3	46.25
Groups C, E, F, G (IIB)				650	12	185
Group D (IIA)				2150	23	370

Special Conditions of Use:

- In Class I, Division 2 installations, the subject equipment shall be mounted within an enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the Canadian Electrical Code (C22.1).*
- In Class I, Zone 2 installations, the equipment shall be installed in a location providing a degree of protection from dust and water greater than or equal to that of an IP54 enclosure.*

To verify the availability of the Approved product, please refer to www.approvalguide.com

KFD2-SL2-Ex1.LK.1045. Single-Channel Solenoid Driver.

NI / I / 2 / ABCD / T4, Ta = 60°C

I / 2 / Ex nA nC / IIC / T4, Ta = 60°C

AIS / I,II,III / 1 / ABCDEFG - 16-562FM-12; Entity

[I / 0] / Ex [ia] / IIC

Entity Parameters: See Table

Gas Group	Voc, Uo (V)	Isc, Io (mA)	Po (mW)	Ca, Co (nF)	La, Lo (mH)	Lo/Ro (uH/Ohm)
Groups A/B (IIC)	26	93	607	99	4.11	58.9
Groups C, E, F, G (IIB)				770	16.4	235.6
Group D (IIA)				2600	32.8	471.2

Special Conditions of Use:

1. In Class I, Division 2 installations, the subject equipment shall be mounted within an enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the Canadian Electrical Code (C22.1).

2. In Class I, Zone 2 installations, the equipment shall be installed in a location providing a degree of protection from dust and water greater than or equal to that of an IP54 enclosure.

KFD2-SL2-Ex1.LK.1270. Single-Channel Solenoid Driver.

NI / I / 2 / CD / T4, Ta = 60°C

I / 2 / Ex nA nC / IIB / T4, Ta = 60°C

AIS / I,II,III / 1 / CDEFG - 16-562FM-12; Entity

[I / 0] / Ex [ia] / IIB

Entity Parameters: See Table

Gas Group	Voc, Uo (V)	Isc, Io (mA)	Po (mW)	Ca, Co (nF)	La, Lo (mH)	Lo/Ro (uH/Ohm)
Groups A/B (IIC)	-	-	-	-	-	-
Groups C, E, F, G (IIB)	22.1	248	1380	1120	2.3	103.65
Group D (IIA)				4140	4.6	207.3

Special Conditions of Use:

1. In Class I, Division 2 installations, the subject equipment shall be mounted within an enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the Canadian Electrical Code (C22.1).

2. In Class I, Zone 2 installations, the equipment shall be installed in a location providing a degree of protection from dust and water greater than or equal to that of an IP54 enclosure



Member of the FM Global Group

Equipment Ratings:

Associated Intrinsically Safe Apparatus (Entity) for connection to Class I, II and III, Division 1, Groups A, B, C, D, E, F and G; Associated Intrinsically Safe Apparatus (Entity) for connection to Class I, Zone 0, [Ex ia] IIC; Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; Temperature Class T4 Ta = 60°C; Class I, Zone 2, Ex nA nC IIC; Temperature Class T4 Ta = 60°C; in accordance with Control Drawing No. 16-562FM-12; Hazardous Locations.

FM Approved for:

Pepperl and Fuchs GmbH
Mannheim, Germany



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 157	1992(R2012)
CSA C22.2 No. 213	1987(R2013)
CSA C22.2 No. 1010-1	2004
E60079-0	2002
E60079-11	2002
E60079-15	2002

Original Project ID: 3036153C

Approval Granted: August 3, 2011

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3050675	July 24, 2014		

FM Approvals LLC

J.E. Marquedant
Manager, Electrical Systems

24 July 2014

Date